

MONOPACK SPORTS FLOOR FINISH

SOLVENT BORNE VERSION

MANUFACTURER:

LBA INDUSTRIES PTY.LTD.
P.O. BOX 59,
LONSDALE S.A. 5160
PHONE: 0418 826 274
FAX: (08) 8392 2786

TRADE NAME AND SYNONYMS:

Sports Floor Finish

HAZARDOUS INGREDIENTS:

Liquid Hydrocarbons Med 10-60%

PHYSICAL DATA:

Specific Gravity 0.93
Vapour Density > Air
Volatiles 50% approx.
Water Soluble No
Flash Point 33 degrees C.

UNUSUAL FIRE & STORAGE HAZARDS:

Use water sprays to cool fire exposed surfaces and adjacent storage vessels.
Remove sources of re-ignition. Extinguish fire.

SPILL OR LEAK PROCEDURES:

Eliminate source of ignition. Ventilate area.
Absorb with sand or suitable material. Transfer to sealed containers with non sparking tools.
Do not allow into drains or water ways.
Wear protective clothing and equipment as required.

WASTE DISPOSAL METHODS:

Dispose in Chemical Waste Disposal Area in accordance with local regulations.

EMERGENCY AND FIRST AID PROCEDURES:

Eyes:

Irrigate eyes thoroughly with water or saline for 15 minutes. Seek medical attention.

Skin:

Wash thoroughly with soap and water. Apply Hand cream/Barrier cream to protect hands.

Inhalation:

Remove to fresh air. Apply artificial respiration if patient not breathing.

Injection:

Do not induce vomiting. Give milk or Liquid Paraffin. Seek medical advice.

SPECIAL PROTECTION INFORMATION:

Avoid heat and flames. Use only in a well ventilated area.
Avoid splashing material to limit possible eye and skin contact.
Use gloves and eye protection where necessary.

TRANSPORT CLASSIFICATION:

Class: 3
Hazchem: 3(Y)
UN Number: 1263
Description: Paint etc. flam.liquid (hfp)
Packaging Group: III

OTHER PRECAUTIONS:

Some plastics may be unsuitable for storage.
Static electricity may occur during container handling.
Avoid repeated or prolonged skin contact.

FIRE FIGHTING PROCEDURES:

Toxic gases may be evolved during fire. Self contained breathing apparatus must be worn. Suitable extinguishing media are Foam, BCF, Dry Chemical or Carbon Dioxide. Water sprays should be used only when required to cool adjacent containers.